

CERTIFICATE OF COMPLIANCE

Certificate Number S480
Report Reference S480-1946-02-21
Date 2022-August-22

Issued to: PROTECTOWIRE CO INC
60 WASHINGTON ST
PEMBROKE MA, 02359-1833 US

This is to certify that representative samples of HEAT-AUTOMATIC FIRE DETECTORS
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 521 - Heat Detectors for Fire Protective Signaling Systems.

CAN/ULC-S530-M91-REV1 - STANDARD FOR HEAT ACTUATED
FIRE DETECTORS FOR FIRE ALARM SYSTEMS

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number S480
Report Reference S480-1946-02-21
Date 2022-August-22

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Model(s):

Fire Alarm Equipment:

USL, CNL - Protectowire line type heat detectors, types PHSC-XXX-EPC, PHSC-XXX-EPR, and PHSC-XXX-XCR, where XXX represents the temperature ratings in the ordinary (155°F, 172°F), intermediate (190°F, 220°F), high (280°F), and extra high (356°F) rating. Type PHSC-135-XLT line type heat detector in the ordinary (135°F) rating. Type PHSC-XXX-LSZH, where XXX represents the temperature ratings in the ordinary (135°F, 155°F, 172°F), intermediate (190°F, 220°F), high (280°F), and extra high (356°F) rating.

USL, CNL - Protectowire line type heat detectors, types PLR-XXX-EPC and PLR-XXX-EPR, where XXX represents the temperature ratings in the ordinary (155°F, 172°F), intermediate (190°F, 220°F), high (280°F), and extra high (356°F) rating. Type PLR-140-XLT line type heat detector in the ordinary (140°F) rating. Type PLR-XXX-XCR line type heat detector, where XXX represents the temperature ratings in the ordinary (155°F, 172°F), intermediate (190°F, 220°F), high (280°F), extra high (356°F), and ultra high (500°F) rating. Type PLR-XXX-LSZH line type heat detector, where XXX represents the temperature ratings in the ordinary (140°F, 155°F, 172°F), intermediate (190°F, 220°F), high (280°F), and extra high (356°F) rating.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

