NOTIFIER
by Honeywell

FST-851, FST-851R, and FST-851H Intelligent Plug-In Temperature Sensors

SPECIFICATIONS

Diameter:	6.1″ (155 mm) installed in B210LP; 4.1″ (104 mm) installed in B501
Height:	2.0″ (51 mm)
Weight:	4.8 ounces (137 gm)
Installation Temperature:	−4°F to 100°F (−20°C to 38°C), FST-851 and FST-851R; −4°F to 150°F (−20°C to 66°C), FST-851H
Operating Humidity Range:	10% to 93% Relative Humidity, Non-condensing
Mounting:	B210LP flanged base; B501 flange less base
Voltage Range:	15 to 32 Volts DC Peak
Standby Current:	300 µA @ 24 VDC (one communication every 5 seconds with LED blink enabled)
LED Current:	6.5 mA @ 24 VDC
Fixed Temperature Rating:	135°F (57°C), FST-851 and FST-851R; 190°F (88°C), FST-851H
Rate-of Rise Detection:	Responds to greater than 15°F/minute; FST-851R

This sensor must be installed in compliance with the control panel system installation manual. The installation must meet the requirements of the Authority Having Jurisdiction (AHJ). Sensors offer maximum performance when installed in compliance with the National Fire Protection Association (NFPA); see NFPA 72.

Before installing sensors, please read the system wiring and installation manual thoroughly. This manual provides detailed information on sensor spacing, placement, zoning, and special applications. Copies of these manuals are available from Notifier.

GENERAL DESCRIPTION

Models FST-851, FST-851R and FST-851H are intelligent sensors that utilize a state-of-the-art thermistor sensing circuit for fast response. These sensors are designed to provide open area protection with 50 foot spacing capability as approved by UL 521. Model FST-851 is a fixed temperature sensor with 135°F fixed temperature alarm. Model FST-851R is a rate-of-rise temperature sensor with 135° F fixed temperature alarm. Model FST-851H is a high temperature sensor with 190° F fixed temperature alarm.

Two LEDs on each sensor light to provide a local, visible sensor indication. Remote LED annunciator capability is available as an optional accessory (Part No. RA400Z/RA100Z).

Notifier panels offer different feature sets across different models. As a result, certain features of the FST-851, FST-851R and FST-851H may be available on some control panels, but not on others. The sensors will support either Flash-Scan™ or CLIP (Classic Loop Interface Protocol) mode. The possible features available, if supported by the control unit include:

1. The panel controls the LED operation on the sensor. Operational modes are RED blink, RED continuous, GREEN blink, and off.
2. The remote output may be synchronized to the LED operation or controlled independent of the LEDs. Please refer to the operation manual for the UL listed control unit for specific operation of these models

Models FST-851, FST-851R, and FST-851H require compatible addressable communications to function properly. Connect these sensors to listed-compatible control panels only.

WIRING GUIDE

All wiring must be installed in compliance with the National Electrical Code, applicable local codes and the Authority Having Jurisdiction. Proper wire gauges should be used. The installation wires should be color coded to limit wiring mistakes and ease system troubleshooting. Improper connections will prevent a system from responding properly in the event of a fire.

Remove power from the communication line before installing sensors.

1. Wire the sensor base (supplied separately) per the wiring diagram, Figure 1.
2. Set the desired address on the sensor address switches, see Figure 2.
3. Install the sensor into the sensor base. Push the sensor into the base while turning it clockwise to secure it in place.

4. After all sensors have been installed, apply power to the control unit and activate the communication line.
5. Test the sensor(s) as described in the TESTING section of this manual.

FIGURE 1. WIRING DIAGRAM:

REMOTE ANNUNCIATOR

CAUTION: DO NOT LOOP WIRE UNDER TERMINAL 1 OR 2. BREAK WIRE RUN TO PROVIDE SUPERVISION OF CONNECTIONS.

UL LISTED COMPATIBLE CONTROL PANEL

CLASS A OPTIONAL WIRING

C0129-02

FIGURE 2:

TENS   ONES

C0162-00

TAMPER RESISTANCE

The sensor base includes a tamper proof feature which when activated prevents removal of the sensor without the use of a tool. See the installation instruction manual for the sensor base for details in using this feature.

TESTING

Before testing, notify the proper authorities that the system is undergoing maintenance, and will temporarily be out of service. Disable the system to prevent unwanted alarms.

All sensors must be tested after installation and periodically thereafter. Testing methods must satisfy the Authority Having Jurisdiction (AHJ). Sensors offer maximum performance when tested and maintained in compliance with NFPA 72.

**A. Test Magnet (Model No. M02-04 - optional)**

1. Place the optional test magnet against the cover in the magnet test area, as shown in Figure 3, to activate the test feature.
2. The LEDs should latch on within 10 seconds, indicating alarm and annunciating the panel.
3. Reset the detector at the system control panel.

B. Direct Heat Method (Hair dryer of 1000 – 1500 watts)

1. From the side of the detector, direct the heat toward the sensor. Hold the heat source about 6 inches (15 cm) away to prevent damage to the cover during testing.
2. The LEDs on the detector should light when the temperature at the detector reaches the alarm setpoint. If the LEDs fail to light, check the power to the detector and the wiring in the detector base.
3. Reset the detector at the system control panel.

Detectors that fail these tests should be cleaned as described under MAINTENANCE and retested. If the detectors still fail these tests, they should be returned for repair.

FIGURE 3. VIEWS SHOWING POSITION OF TEST MAGNET:

C0196-00

MAINTENANCE

NOTE: Before cleaning notify the proper authorities that the system is undergoing maintenance, and therefore the system will temporarily be out of service. Disable the loop or system undergoing maintenance to prevent unwanted alarms.

It is recommended that the sensor be removed from its mounting base for easier cleaning and that sensors be cleaned at least once a year. Use a vacuum cleaner to remove dust from the sensing chamber.

FIGURE 4:

C0197-00

FM CLASSIFICATION

RTI ratings are for installations which must comply with FM 3210.

FST-851 RTI:	FAST
FST-851R RTI:	V2-FAST
FST-851H RTI:	QUICK

Please refer to insert for the Limitations of Fire Alarm Systems